

Product Data Sheet 4484 FD

ebmpapst

The engineer's choice



4484 FD

INDEX

| | | |
|----------|---------------------------------|----------|
| 1 | General | 3 |
| 2 | Mechanics | 3 |
| 2.1 | General..... | 3 |
| 2.2 | Connections..... | 3 |
| 3 | Operating Data | 4 |
| 3.1 | Electrical Operating Data | 4 |
| 3.2 | Electrical Features | 4 |
| 3.3 | Aerodynamics..... | 6 |
| 3.4 | Sound Data..... | 7 |
| 4 | Environment | 7 |
| 4.1 | General..... | 7 |
| 4.2 | Climatic Requirements | 7 |
| 5 | Safety | 8 |
| 5.1 | Electrical Safety | 8 |
| 5.2 | Approval Tests | 8 |
| 6 | Reliability | 8 |
| 6.1 | General..... | 8 |

1 General

| | | |
|-------------------------------------|------------------------|--|
| Fan type | Fan | |
| Rotating direction looking at rotor | Counterclockwise | |
| Airflow direction | Air outlet over struts | |
| Bearing system | Ball bearing | |
| Mounting position - shaft | Any | |


2 Mechanics

2.1 General

| | | |
|---|---|--|
| Width | 119,0 mm | |
| Height | 119,0 mm | |
| Depth | 25,4 mm | |
| Mass | 0,165 kg | |
| Housing material | Plastic | |
| Impeller material | Plastic | |
| Max. torque when mounted across both mounting flanges | Wire outlet corner: 100 Ncm Remaining corners: 130 Ncm | |
| Screw size | ISO 4762 - M4 degreased, without an additional brace and without washer | |

2.2 Connections

| | | |
|-----------------------|-------------|--|
| Electrical connection | Plug | |
| Lead wire length | See drawing | |
| Tolerance | | |
| Plug | See drawing | |
| Contact | See drawing | |



3 Operating Data

3.1 Electrical Operating Data


Measurement conditions: Normal air density = 1,2 kg/m³; Temperature 23°C +/- 3°C; Motor axis horizontal; warm-up time before measuring 5 minutes (unless otherwise specified). In the intake and outlet area should not be any solid obstruction within 0,5 m.

$\Delta p = 0$: corresp. to free air flow (see chapter aerodynamics)
 I: corresp. to arithm. mean current value

| Features | Condition | Symbol | Values | | |
|---------------------|----------------|----------------|-------------|-------------|-------------|
| Voltage range | | U | 12,0 V | | 28,0 V |
| Nominal voltage | | U _N | | 24,0 V | |
| Power consumption | $\Delta p = 0$ | P | 1,1 W | 5,0 W | 7,0 W |
| Tolerance | 0010 | | +/- 17,5 % | +/- 12,5 % | +/- 15,0 % |
| Current consumption | $\Delta p = 0$ | I | 95 mA | 210 mA | 250 mA |
| Tolerance | 0010 | | +/- 17,5 % | +/- 12,5 % | +/- 15,0 % |
| Speed | $\Delta p = 0$ | n | 1.700 1/min | 2.900 1/min | 3.200 1/min |
| Tolerance | 0010 | | +/- 12,5 % | +/- 7,5 % | +/- 10,0 % |

3.2 Electrical Features

| | | |
|---|---|--|
| Electronic function | None | |
| Reversed polarity protection | Rectifying diode | |
| Max. residual current at U _N | I _F < 100 uA | |
| Locked rotor protection | Auto restart | |
| Locked rotor current at U _N | I _{block} approx. 300 mA | |
| Clock signal at locked rotor | t ₃ / t ₄ typical: 0,6 s / 10 s | |



Block1: special locked rotor protection: 5 cycles t₃ / t₄ = 0,6 s / 0,5 s Block2: locked rotor protection t₃ / t₄ = 0,6 s / 10 s

3.3 Aerodynamics

Measurement conditions:

Measured with a double chamber intake rig acc. to DIN EN ISO 5801.

Normal air density = 1,2 kg/m³; Temperature 23°C +/- 3°C;


In the intake and outlet area should not be any solid obstruction within 0,5 m. Motor shaft horizontal.

The information is only valid under the specified test conditions and may be changed by the installation conditions. If there are deviations from the standard test conditions, the characteristic values must be checked under the installed conditions.

a.) Operation condition:

2.900 1/min at free air flow

| | | |
|---|-----------------------|--|
| Max. free-air flow ($\Delta p = 0 / \dot{V} = \max.$) | 168 m ³ /h | |
| Max. static pressure ($\Delta p = \max. / \dot{V} = 0$) | 61 Pa | |



3.4 Sound Data

Measurement conditions: Sound pressure level: 1 meter distance between microphone and the air intake.
 Sound power level: Acc. to DIN 45635 part 38 (ISO 10302)
 Measured in a semianchoic chamber with a background noise level of $L_p(A) < 5 \text{ dB(A)}$
 For further measurement conditions see chapter aerodynamics.

a.) Operation condition:

| | | |
|---|-------------------------------|--|
| 2.900 1/min at free air flow | | |
| Optimal operating point | 129 m ³ /h @ 19 Pa | |
| Sound power level at the optimal operating point | 5,4 bel(A) | |
| Sound pressure level at free air flow, measured in rubber bands | 43 dB(A) | |

4 Environment

4.1 General

| | | |
|--|--------|--|
| Min. permitted ambient temperature TU min. | -20 °C | |
| Max. permitted ambient temperature TU max. | 60 °C | |
| Min. permitted storage temperature TL min. | -40 °C | |
| Max. permitted storage temperature TL max. | 80 °C | |

4.2 Climatic Requirements

| | | |
|-----------------------|---|--|
| Humidity requirements | humid heat, constant; according to DIN EN 60068-2-78, 14 days | |
| Water exposure | None | |
| Dust requirements | None | |
| Salt fog requirements | None | |

Permitted application area:

The product is intended for use in sheltered rooms with controlled temperature and controlled humidity. Directly exposure to water must be avoided.

Pollution degree 1 (according DIN EN 60664-1)

There is either no pollution or it occurs only dry, non-conductive pollution. The pollution has no negative impact.

Please require severity levels and specification parameters from the responsible development departments.

5 Safety

5.1 Electrical Safety

| | | |
|--|------------------|--|
| Dielectric strength DIN EN 60950 (VDE 0805) and DIN EN 60335 (VDE 0700) A.) Type test Measuring conditions: After 48h of storage at 95% R.H. and 25°C. No arcing or breakdown is allowed! All connections together to ground. | 500 VAC / 1 Min. | |
| B.) Routine test Measuring conditions: At indoor climate. No arcing or breakdown is allowed! All connections together to ground. | 850 VDC / 1 Sec. | |
| Isolation resistance Measuring conditions: After 48h of storage at 95% R.H. and 25°C measured with U=500 VDC for 1 min. | RI > 10 MOhm | |
| Clearance / creepage distance | 1,0 mm / 1,2 mm | |
| Protection class | III | |

5.2 Approval Tests

| | | |
|-----|---|---|
| CE | EC Declaration of Conformity | Yes |
| EAC | Eurasian Conformity | Yes |
| UL | Underwriters Laboratories | Yes / UL507, Electric Fans |
| VDE | Association for Electrical, Electronic and Information Technologies | Yes / Approval acc. to EN 60950 (VDE 0805) - Information technology equipment |
| CSA | Canadian Standards Association | Yes / C22.2 No. 113 Fans and Ventilators |
| CCC | China Compulsory Certification | Not applicable |

6 Reliability

6.1 General



| | | |
|--|-----------|--|
| Life expectancy L10 at TU = 40 °C | 60.000 h | |
| Life expectancy L10 at TU max. | 37.500 h | |
| Life expectancy L10 acc. to IPC 9591 at TU = 40 °C | 102.500 h | |

Copying of this document, and giving it to others and the use or communication of the contents thereof, are forbidden without express authorisation. Offenders are liable to the payment of damages. All rights are reserved in the event of the grant of a patent or the registration of a utility model or design.


Schutzmerk nach DIN 34 beachten

082
210
232
235
240
243
315x
516


Steckermaße
M2:1




Steckerlage B



Ausführung F



Ausführung FD



Ⓒ
Ⓓ

| Erzeugnis-Nr. | Typ | Lagersystem K=Kugellager C=Gleitlager | Geißel- ausführung | Steckerlage | Steckermaße |
|---------------|----------|---|-----------------------|-------------|----------------|
| 929 3505 400 | 4484 F | K | F | B | D 0.5 E 8.5 |
| 929 3505 402 | 4484 FD | K | FD | B | 0.5 8.5 |
| 929 3505 403 | 4484 FM | K | F | B | 0.5 8.5 |
| 929 3505 404 | 4484 FMD | K | FD | B | 0.5 8.5 |
| 929 3505 411 | 4482 FM | K | F | B | 0.5 8.5 |
| 929 3505 412 | 4482 FMD | K | FD | B | 0.5 8.5 |
| 929 3505 426 | 4484 FG | C | F | B | 0.5 8.5 |
| 929 3505 439 | 4482 FGM | C | F | B | 0.5 8.5 |

1) Maße für Montagewand
Axialspiel bei
Kugellagerung (K) : 0 (mit Federausgleich)
Gleitlagerung (G) : 0.1 – 0.6

Allgemeinheiten

| Erstellt | Datum | Name | Artikel |
|---|-------|-------------------------|-----------------------------------|
| Geprüft | | F?rst/K.N. Wrobel G. | Maßstab 1:1 (2:1) |
| a. Eröffnung 20.02.97, Kiennauer b. Eröffnung 13.05.96, Kiennauer Index, Zed.-Nr., Datum, Beförderer von Zur Verwendung im Verteiler freigegeben von KOLETZKI M. am | | | Zehj.-Nr. |
| PAPST PAPST-MOTOREN GmbH & Co D-7612 St. Georgen Germany | | | Ers.Zehj.- g.I.Nr.v. 17.06.94 : A |

F?rdrichtung